

試 驗 報 告

報告編號：TB-18-03297

C-18-09012

頁 數：1 OF 1

報告日期：107年06月13日

工 程 名 稱：自測
 承 包 商：-----
 委 託 單 位：鑑麟實業股份有限公司
 供 料 廠 商：-----
 样 品 名 稱：stoneflor 史東 XL 磚石卡扣地板
 送 驗 人 員：鑑麟實業股份有限公司-鄭敬容
 收 件 日 期：107年06月07日
 試 驗 日 期：107年06月07日~107年06月13日
 备 註：1.以上資料由顧客提供(收件及試驗日期除外)
 2.除非另有說明，此報告結果僅對測試之樣品負責
 未經本公司事先書面同意，此報告不可部分複製

試 驗 結 果：

試驗項目	試驗結果	CNS 7614(1994) 防焰一級規範值	CNS 7614(1994) 防焰二級規範值	CNS 7614(1994) 防焰三級規範值	試驗方法
火源加熱時間 (sec)	10	-----	-----	-----	CNS 7614(1994) A法
餘焰時間 (sec)	0.0	≤ 1	≤ 5	≤ 5	
餘燼時間 (sec)	0.0	≤ 60	≤ 60	≤ 60	
炭化長度 (cm)	0.0	≤ 5	≤ 10	≤ 15	

註：1.樣品平均厚度 5.5 mm

2.試驗者：陳彥融

3.測試面為正面

4.本試驗之樣品厚度不在TAF認可範圍內，故無法出具TAF標誌之報告



本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

TWC4629408

試驗報告

報告編號：PL-17-00210X

報告頁數：1 of 1

報告日期：106 年 08 月 25 日

委 託 單 位：長田實業股份有限公司

樣 品 名 稱：太格 PVC 複合地板

產 品 型 號：LG Durable 地寶系列

收 件 日 期：106 年 08 月 18 日

試 驗 日 期：106 年 08 月 18 日~106 年 08 月 25 日

試驗內容：

試驗項目	單位	試驗結果	規範值			試驗方法
			防焰 1 級	防焰 2 級	防焰 3 級	
火源加熱時間	sec	10	-	-	-	參考 CNS 7614 : 1994
碳化長度	cm	2.7	≤5	≤10	≤15	
餘焰時間	sec	0.0	≤1	≤5	≤5	
餘燼時間	sec	0.0	≤60	≤60	≤60	

註：樣品平均厚度約 2 mm。

以下空白



張繼文
報告簽署人

本報告若有規範要求值，該要求值由顧客提供僅供參考，合格判定以實際驗收要求為準。

本報告除非另有說明，報告結果僅對送驗樣品負責，不得部份複製使用。